

ORIGINAL



0000170160

BEFORE THE ARIZONA CORPORATION COMMISSION

RECEIVED

COMMISSIONERS

DOUG LITTLE – Chairman
BOB STUMP
BOB BURNS
TOM FORESE
ANDY TOBIN

2016 MAY -6 P 4: 20

AZ CORP COM. DIV.
DOCKET CONTROL

IN THE MATTER OF THE APPLICATION OF
HYDRO-RESOURCES, INC. FOR A RATE
INCREASE.

DOCKET NO. W-20770A-16-0020

STAFF'S NOTICE OF FILING

Attached is an email communication sent to Staff from Hydro-Resources, Inc. in response to Staff's Engineering Recommendation (2) discussing the cost of automatic fire pump control system modification costs.

RESPECTFULLY SUBMITTED this 6th day of May 2016.

Arizona Corporation Commission

DOCKETED

MAY 06 2016

DOCKETED BY

For

Robin R. Mitchell, Attorney
Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007
(602) 542-3402

Original and thirteen (13) copies
of the foregoing filed this
6th day of May 2016 with:

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

1 Copy of the foregoing emailed this
6th day of May 2016 and mailed on
2 The 9th day of May, 2006 to:

3 Rodney Ott
Quarles & Brady LLP
4 Two North Central Avenue
One Renaissance Square
5 Phoenix, Arizona 85004
6 rwott@bryancave.com

7 John Rueter
801 South State Route 64
8 Space 100
9 Williams, Arizona 86406
john@jwrueter.com

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28



The following was a communication between Staff and the Company in regards to fire pump automatic control systems modifications.

Michael Thompson initially had a phone conversation with Mr. Rueter, Wednesday morning, May 4th :

Hello Mr. Rueter, regarding the fire pump automatic control system modification, the Utility Division Director would like to know the total estimated cost associated with its installation. Would you be able to provide that information to me by this afternoon? I'm not certain, but the costs associated with the fire pump control system may be included in the rate case.

Mr. Rueter responded via email with the following:

-----Original Message-----

From: John Rueter

Sent: Wednesday, May 04, 2016 2:11 PM

To: Michael Thompson

Subject: Fire pump automatic start modifications

Hello Mike,

In response to your question concerning the modification to allow remote and automatic operation of the Hydro-Resources fire pump in Tusayan, we estimate a total \$14,580.00 at this time for completion of all work.

This will include running communications wire from Hwy 64 up to the fire pump and tank site, technician costs, excavation and installation of a pressure sensing device and control box on the 8' waterline at the electrical panel at the bottom of the hill, and a visible warning light along with remote alarms for both Hydro Resources staff and the local fire department.

Should you have any further questions don't hesitate to call.

Kind Regards,

John Rueter

President

Hydro Resources Inc.